



To: Prospective Bidders  
Date: November 14, 2022

RE: Addendum No. 2  
Back up Generator Installation  
(Q House)  
ITB # SCF23-1083

Issue Date: October 19, 2022

This document forms a part of the Contract Documents and modifies the original Procurement Documents dated October 19. Acknowledge receipt of this Addendum in the provided on the Bid Form. Failure to acknowledge receipt of this addendum may subject Proposers to disqualification.

This Addendum consists of one (1) page.

---

1. Response to final bidder question.

Will temporary power be required on this project during the conversion?	Yes, temporary power to the building will be needed during the day(s) of the conversion so normal services provided in the building may continue uninterrupted.
---	---