



SCF Contracts Department
7033 East Tudor Road
Anchorage, AK 99507

To: Prospective Bidders
Date: July 11, 2023

RE: Addendum No. 2
PCC Garage Façade
ITB # SCF23-1103

Issue Date: June 15, 2023

This document forms a part of the Contract Documents and modifies the original Procurement Documents dated June 15, 2023. Acknowledge receipt of this Addendum in the provided on the Bid Form. Failure to acknowledge receipt of this addendum may subject Proposers to disqualification.

This Addendum consists of two (2) pages.

1. Responses to bidder questions

SCF responses to the bidder questions received after the site visit on June 29 are provided below:

Item No.	Date Received	Comment or Question Provided by Bidder	SCF Response
1	30-Jun	on Sheet A2.11: Does the building signage that SCF is providing require power?	Yes, the signage has electric.
2	30-Jun	on Sheet A2.11: Has SCF permitted the signage or is the contractor responsible for the permit?	Contractor is responsible.
3	5-Jul	<p>Please have design team address the issue:</p> <ul style="list-style-type: none"> - <u>G1.00 Assembly Type F states the exterior finish system BOD: Glen-Gery Tru-Brix Wall System.</u> - <u>A2.10 and A2.11 Legend -Brick Colors lists Belden Brick Company as the BOD.</u> The distributor for Belden Brick Company in Oregon advised that the thin brick manufacturer that their brick is not compatible with the track that is specified. 	<p>Glen-Gery has made an exception for this project and will groove the specified Belden Brick for use in their True-Brix system. The general contractor will be responsible for procuring the Belden brick and facilitating transport to and from Glen-Gery's facility in Shoemakersville, PA. Additionally, Glen-Gery is suggesting a 7 – 10% overage to account for breakage during the shipping and grooving process. For more information, please contact:</p> <p>Mike Ivosevich Specialist, Tru-Brix Direct +1 (301) 223-8647 Cell 301-991-9437 Email Mike.Ivosevich@glengery.com</p> <p>Glen-Gery Cushwa Plant 15718 Clear Spring Road Williamsport, MD 21795</p>