



To: Prospective Bidders
Date: December 4, 2024

RE: Addendum No. 2
Denali Parking Garage Glass
Cladding Removal & Disposal
RFP # SCF25-1152

Issue Date: November 22, 2024

This document forms a part of the Contract Documents and modifies the original Procurement Documents dated November 22, 2024. Acknowledge receipt of this Addendum in the provided on the Bid Form. Failure to acknowledge receipt of this addendum may subject Proposers to disqualification.

This Addendum consists of one (1) page.

1. Responses to bidder questions:

#	Comment or Question Provided by Bidder	SCF Response
1	Do you know if there is 220-volt power somewhere in the Garage?	Please refer to Exhibit F - CDCB Parking Structure only Record Drawings Electrical Sheets. Panels serving Garage are 480/277 Wye and 120/208 Wye. Receptacles are fed from the 120/208 Wye panels.
2	Where could we park a large dumpster near the site for the old glass?	A dumpster can be parked near 4155 Tudor Centre and 4175 Tudor Centre. SCF will coordinate location with selected contractor.
3	Is there any possibility of extending the completion date out to May 1st?	No.